

Q & A – Washington County R&B District Facility Design RFP

1. Fire Suppression system in the whole building? – Yes
2. Storage Area Location and Details?
 - a. Next/adjacent to the Maintenance bays, not near the offices
 - b. Containment area for liquid chemicals
 - c. Storage of flammable chemicals in locked area
3. Floor heat? – Yes
4. Air Compressor tank or system? – system plumbed into and throughout the Maintenance area and a couple outlets in the Vehicle Storage area.
5. Overhead doors? – 16 feet wide, 18 feet tall and sidewalls of building 20 feet high
6. Building design to include sidewalks areas and aprons to shop/overhead doors – no landscaping
7. Timeline of project? – more detailed timeline expected in the fall with the project bids
8. Resumes' – relevant licensing and experience, examples of similar projects. Preliminary listing of project personnel – with full listing expected in the fall with full bids.